

ORDINANCE NO. 1589

AN ORDINANCE WAIVING COMPETITIVE BIDDING FOR THE PURCHASE OF A WEDGEWATER FILTER BED SYSTEM FOR THE WASTEWATER TREATMENT PLANT AND DECLARING AN EMERGENCY

BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF EUREKA SPRINGS, ARKANSAS, THAT:

Section One: Competitive Bidding Waived

Pursuant to Title 3, Section 3.04.02, Purchases, More Than Five Thousand Dollars, of the Municipal Code, the competitive bidding requirements are hereby waived for the purchase of a Wedgewater Filter Bed System to rehabilitate an existing drying bed at the Eureka Springs Wastewater Treatment Plant. The cost shall not exceed \$30,000.

Section Two: Contract Authorization

McClelland Consulting Engineers, Inc., the firm engaged by the City to oversee improvements at the Wastewater Treatment Plant, has recommended said purchase; and the Mayor and the Clerk/Treasurer are hereby authorized and directed to contract with Instrument & Supply, Inc., Hot Springs, AR, for the purchase.

Section Three: Repeal Clause

All Ordinances or Resolutions, and parts thereof, in conflict herewith are hereby repealed to the extent of such conflict.

Section Four: Emergency Clause

The City Council of the City of Eureka Springs finds that this product is not available from any other provider, and the system is necessary for the improvement of the Plant's operations and the welfare of the public. Therefore, an emergency is declared; and this ordinance shall be in force and effect from and after the date of its publication.

PASSED AND ORDAINED BY THE CITY COUNCIL OF THE CITY OF EUREKA SPRINGS, ARKANSAS, THIS 26th DAY OF April, 1994.

APPROVED:

Louise O. Berry
Louise O. Berry, Mayor

ATTEST:

Juanita S. Barner
Juanita S. Barner, City Clerk

city of eureka
springs



city offices, 44 south main
eureka springs, arkansas 72632

phone
501-253-9703

April 11, 1994

Mr. Paul Selig
Instrument & Supply, Inc.
P.O. Box 1678
Hot Springs, AR 71902

Re: GFS Proposal No. 032394-1
Wedgewater Filter Bed System

Dear Paul:

Please consider this your authorization to proceed with delivery of the items appearing in the referenced Proposal. We understand that the price of \$26,950.00 is firm and we agree to the terms of the Proposal, with the following notations/exceptions:

1. In addition to the ordered quantity of block media, we understand that we are to receive at least five (5) spare blocks for future maintenance purposes.
2. All blocks are to be of standard (12" x 12") size, except the northern-and-western-most rows of blocks are to be factory-cut (by you, prior to shipment) to a dimension of 8" and 2", as measured in the east/west and north/south directions, respectively. This will make the "block area" of the refurbished drying bed measure 23'-8" (E/W) x 31'-2" (N/S). Therefore, the bed will have a total block area of approximately 740 SF.
3. A written request has been made of ADPC&E to exempt from Sales Tax the purchase of this equipment under Arkansas Code 26-53-114 because the equipment/materials will be used to reduce water pollution.

If you have questions, please contact the undersigned, or Mr. Bob Bryant of McClelland Consulting Engineers (phone: 501-443-2377).

Sincerely,

Kirby Murray
Director of Public Works

USE PO # 22211