

**ORDINANCE NO. 1621**

**AN ORDINANCE WAIVING COMPETITIVE BIDDING REQUIREMENTS FOR PURCHASING A TERTIARY FILTRATION SYSTEM FOR THE EUREKA SPRINGS WASTEWATER TREATMENT PLANT AND DECLARING AN EMERGENCY**

**WHEREAS**, the Arkansas Department of Health has recommended the installation of a tertiary filtration system at the Eureka Springs Wastewater Treatment Plant; and

**WHEREAS**, filtration is one way of reducing microbiological pathogens in the wastewater effluent which are resistant to disinfection and which could be transmitted to the groundwater; and,

**NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF EUREKA SPRINGS, ARKANSAS, THAT:**

**Section One: Competitive Bidding Requirements Waived**

Pursuant to Title 3, Section 3.04.02, "Purchases, More Than Five Thousand Dollars," of the Municipal Code, the competitive bidding requirements are hereby waived for the purchase of one Aqua-Aerobic System, Inc., Model A6-DP Six-disk Package Type AquaDisk Tertiary Filter including disks with cloth membranes, backwash system, high-pressure spray cleaning system, solids-removal system, drive mechanism, and electrical controls suitable for operation on 3/60/230 volt power. The total delivered price of said system shall not exceed \$155,000.00, plus taxes. The system is available only through Aqua-Aerobic Systems, Inc., Germantown, Tennessee.

**Section Two: Repeal Clause**


All Ordinances or Resolutions, and parts thereof, in conflict herewith are hereby repealed to the extent of such conflict.

**Section Three: Emergency Clause**


The City Council of the City of Eureka Springs, Arkansas, hereby determines and declares that an emergency exists by reason of necessity of maintaining the integrity of the Wastewater Treatment Plant and that the immediate effects of the provisions of this Ordinance are necessary to preserve the health, safety, and welfare of the public. This Ordinance, therefore, shall be in full force and effect as of the date of its adoption.

**PASSED AND ORDAINED BY THE CITY COUNCIL OF THE CITY OF EUREKA SPRINGS, ARKANSAS, THIS 9th DAY OF August, 1994.**

APPROVED:

  
\_\_\_\_\_  
Louise O. Berry, Mayor

ATTEST:

  
\_\_\_\_\_  
Juanita S. Barner, City Clerk

C B

RECEIVED AUG - 4 1994

JIM GUY TUCKER  
GOVERNOR*Arkansas* DEPARTMENT OF HEALTH4815 WEST MARKHAM STREET • LITTLE ROCK, ARKANSAS 72205-3867  
TELEPHONE AC 501 661-2000SANDRA B. NICHOLS, M.D.  
DIRECTOR

July 29, 1994

McClelland Consulting Engineers, Inc.  
1810 N. College Avenue  
P. O. Box 1229  
Fayetteville, Arkansas 72702RE: Preliminary Engineering Report  
Tertiary Filtration  
Eureka Springs Sewer  
Eureka Springs, AR  
94-4929

Gentlemen:

The preliminary engineering report submitted for the project referenced above has been reviewed by this office and we concur with the proposal in general.

One set of the plans is being returned. The other set is being retained for our files.

When submitting correspondence pertaining to this project, please include our reference number 94-4929.

Sincerely,

A handwritten signature in cursive script, appearing to read "Robert Hart".

Robert Hart, P.E.  
Chief Engineer  
Division of Engineering

RH:MM:TLB:1km

cc: Carroll County Sanitarian  
Protective Health Codes  
Eureka Springs Wastewater

ID#2259/15-16

*"An Equal Opportunity Employer"*